

STAIRCASE INSPECTION

STAIRCASE OWNER: _____

PERMIT NUMBER: _____

ANCHORAGE:

Staircase shall be secured to shoreline with adequate anchorage to prevent lateral or vertical movement.

Staircase shall not be anchored to living and/or dead vegetation to include trees or brush.

Staircase shall not be anchored to buildings or other structures.

STAIRCASE:

Check stairway for any material or obstruction, which would be unsafe.

Check conditions of all stairways/steps to insure they are secure with welds, sheet metal, or steel plates to resist movement that would tend to dismantle structure (25-lbs/sq ft wind load).

Stairway cannot be less than 3 feet wide.

HANDRAILS:

Handrails shall be structurally sound and maintained in a state of good repair and free of splinters.

Stairways shall have a minimum of one handrail 42" high the entire length of the stairway.

Handrails shall have a minimum of one support rod placed every four feet on center.

METAL FINISH:

Check all metal for excessive damage.

Check metal surfaces for need of repainting.

PERMIT:

Current Corps permit properly posted.

Signature of Inspector

Date

Signature of Permit Holder